

**ROMCABLU**

ROMCABLU Srl.

vanzari@romcablu.com - rom.cablu@hotmail.com
www.romcablu.com www.rom-cablu.ro

Cordoane flexibile cu izolatie si manta din PVC Flexible cords PVCinsulated MYYM | H05VV-F



Constructie

Conductor flexibil din cupru, clasa5
Izolatie dinPVC
Manta dinPVC

Specificatia tehnica

Tensiunea nom.: 300/500 V

Temperatura minima:

- instalare si manipulare: +5 °C
- depozitare: -40 °C

Temperatura max. de depozitare: +40 °C

Temperatura de lucru: min. -25 °C max. +70 °C

Utilizare: conectarea aparaturii casnice si de birou, supuse la solicitari medii, in medii umede

Culoarea mantalei: alb, negru

Standard de fabricatie: HD 21.5.S3

Identificare conductori conf. VDE 0293, HD 308

Ambalare: colaci de 100, tamburi de lemn.

Construction

Stranded copper conductor, class5
PVCinsulation
PVCsheath

Technical specification

Rated voltage: 300/500 V

Min. perm. temp.

- with installation and handling: +5 °C
- storage: -40 °C

Max.perm. storage temp.:+40 °C

Operating temperature:min-25°C,max+70°C

Use: Connections of household and office electrical appliances working with medium mechanical stress, connections of appliances working in humid and wet rooms.

Colour of sheath: white, black

Manufactured according to: HD 21.5.S3

Core identification acc. to VDE 0293, HD 308

Packing: coils 100 m,reels

Conductor Cores (n _x mm ²)	Forma (Shape) conducto	Gr.izolatie Insulation thick.(mm)	Gr. manta (mm) sheath thick.(mm)	exterior Ø Outer (mm)	Cupru Copper kg/km	Cablu Cable kg/km
2X0.5	rm	0.6	0.7	5.7	8	46
2X0.75	rm	0.6	0.7	6.1	12	55
2X1	rm	0.6	0.7	6.4	17	63
2X1.5	rm	0.7	0.7	7.4	25	86
2X2.5	rm	0.8	0.9	9.1	42	133
2X4	rm	0.8	0.6	10.2	68	179
2X6	rm	0.8	0.8	12.6	99	262
2X10	rm	1	1.25	17.1	174	475
2X16	rm	1	1.25	19.3	269	638
3X0.5	rm	0.6	0.7	6	13	54
3X0.75	rm	0.6	0.7	6.5	19	65
3X1	rm	0.6	0.7	6.8	25	77
3X1	rm	0.6	0.8	7.9	38	108
3X1.5	rm	0.7	0.8	8.1	37	108
3X2.5	rm	0.8	0.9	9.7	62	162
3X4	rm	0.8	0.7	11.1	102	227
3X6	rm	0.8	0.8	13.4	149	323
3X10	rm	1	1.25	18.2	261	582
3X16	rm	1	1.25	20.5	403	792
4X0.5	rm	0.6	0.7	6.6	17	66

Conductor Cores (n _x mm ²)	Forma (Shape) conducto	Gr.izolatie Insulation thick.(mm)	Gr. manta (mm) sheath thick.(mm)	exterior Ø Outer (mm)	Cupru Copper kg/km	Cablu Cable kg/km
4X1	rm	0.6	0.8	7.7	34	98
4X1.5	rm	0.7	0.9	9.1	49	138
4X2.5	rm	0.8	1	10.8	83	207
4X4	rm	0.8	0.8	12.4	136	290
4X6	rm	0.8	0.8	14.8	199	404
5X0.75	rm	0.6	0.5	7.9	31	101
5X1	rm	0.6	0.6	8.6	42	123
5X1.5	rm	0.7	0.6	9.9	62	167
5X2.5	rm	0.8	0.7	11.9	104	251
5X4	rm	0.8	0.8	13.5	169	354
5X6	rm	0.8	1.25	17.5	249	547
7X1	rm	0.6	0.9	9.4	59	152
7X1.5	rm	0.7	1	11	86	214
7X2.5	rm	0.8	1.1	13.1	145	323
9X1.5	rm	0.7	1.1	13.6	111	310
9X2.5	rm	0.8	1.5	16.9	187	490
12X1.5	rm	0.7	1.1	14.7	148	376
12X2.5	rm	0.8	1.5	18.2	249	594